


Note: Grounded conductor/neutral is a pass-through and is not terminated in the meter socket.

SERVICE PANEL



LINE



LOAD

EV CHARGER



This information is for general purposes only and is not intended to serve as a set of specifications for installation of the equipment. All installations shall be completed by a licensed electrician in compliance with the National Electric Code/ National Electric Safety Code. MVEC is not responsible for installation or any damages associated therewith.

 MVEC MINNESOTA VALLEY ELECTRIC COOPERATIVE A Touchstone Energy® Cooperative	EV Wiring Diagram Single Load				
	MINNESOTA VALLEY ELECTRIC COOPERATIVE JORDAN, MN				
DATE	8/3/26	DWG BY:	EV-1		
PROJECT NO.	— —	SCALE	N/A	CHKD BY:	APPD BY:
				SHEET	