


Note: Grounded conductor/neutral is a pass-through and can be terminated in the meter socket. If the terminal is utilized, the bonding jumper must be removed.

MAIN SERVICE PANEL



LINE



LOAD

SUB PANEL



EV CHARGER



EV CHARGER



This information is for general purposes only and is not intended to serve as a set of specifications for installation of the equipment. All installations shall be completed by a licensed electrician in compliance with the National Electric Code/ National Electric Safety Code. MVEC is not responsible for installation or any damages associated therewith.

 MINNESOTA VALLEY ELECTRIC COOPERATIVE A Touchstone Energy® Cooperative	EV Wiring Diagram Multiple Loads			
	MINNESOTA VALLEY ELECTRIC COOPERATIVE JORDAN, MN			
DATE 8/3/26	DWG BY:	DWG NO. EV-2		
PROJECT NO. — —	SCALE N/A	CHKD BY:	APPD BY:	SHEET